

SOUTHERN ANALYTICAL LABORATORIES, INC.

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-2218

Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format



Water Boy, Inc.
Annual Source Spring Analyses

LABORATORY CERTIFICATION INFORMATION (to be completed by lab - please type or print legibly)
Lab Name: Southern Analytical Laboratories, Inc. Florida DOH Certification #: E84129
Certification Expiration Date: 06/30/2014

Address: 110 Bayview Blvd Oldsmar, FL 34677

Phone: (813) 855-1844

Were any analyses subcontracted? Yes No

If yes, please provide DOH certification number(s): E87688

ATTACH CURRENT DOH ANALYTE SHEET*

ANALYSIS INFORMATION (to be completed by lab)

Date Sample(s) Received: 03/05/2014

1402335-01

PWS ID (From Page 1):

Sample Number (From Page 1):

1402335-01

Lab Assigned Report # or Job ID:

1402335-01

Group(s) Analyzed & Results attached for compliance with Chapter 62-550, F.A.C. (Check all that apply):

Inorganics
 All Except for Asbestos
 Partial
 Nitrate
 Nitrite
 Asbestos

Synthetic Organics
 All 30
 All Except Dioxin
 Partial
 Dioxin Only

Volatile Organics
 All 21
 Partial

Disinfection Byproducts
 Trihalomethanes
 Haloacetic Acids
 Chlorite
 Bromate

Radionuclides
 Single Sample
 City Composite

Secondaries
 All 14
 Partial

LAB CERTIFICATION

I, Francis I. Daniels (Print Name)

Laboratory Director (Print Title)

do HEREBY CERTIFY

that all attached analytical data are correct and unless noted meet all requirements of the National Environmental Laboratory Accreditation Conference (NELAC).

Signature: Francis I. Daniels

Date: 03/20/2014

- * Failure to provide a valid and current Florida DOH lab certification number and a current Analyte Sheet for the attached analysis results will result in rejection of the report, possible enforcement against the public water system for failure to sample, and may result in notification of the DOH Bureau of Laboratory Services.
- ** Please provide radiological sample dates & locations for each quarter:

CONFIRMATION & NOTIFICATION IS REQUIRED WITHIN 24 HOURS FOR NITRATE AND NITRITE MCL EXCEEDANCES

NON-DETECTS ARE TO BE REPORTED AS THE MDL WITH A "U" QUALIFIER (Non-detects reported as "BDL" or with a "<" are not acceptable.)

COMPLIANCE DETERMINATION (to be completed by DEP or DOH - attach notes as necessary)

Sample Collection & Analysis Satisfactory: Yes No

Replacement Sample or Report Requested (circle or highlight group(s) above)

Person Notified: _____

Date Notified: _____

DEP/DOH Reviewing Official: _____

H2O Quality yearly Analytic



**Florida Department of Environmental Protection
 Safe Drinking Water Program Laboratory Reporting Format**

INORGANIC CONTAMINANTS
 62-550.310(1)

Report Number / Job ID: 1402335-01
 PWS ID (From Page 1): _____

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1040	Nitrate (as N)	10	mg/L	0.06		EPA 300.0	0.01	3/6/14	3:26	E84129
1041	Nitrite (as N)	1	mg/L	0.09		EPA 300.0	0.01	3/6/14	3:26	E84129
1005	Arsenic	0.010	mg/L	0.00093	U	EPA 209.8	0.00093	3/11/14	16:49	E84129
1010	Barium	2	mg/L	0.014		EPA 200.8	0.00018	3/11/14	16:49	E84129
1015	Cadmium	0.005	mg/L	0.00027	U	EPA 200.8	0.00027	3/11/14	16:49	E84129
1020	Chromium	0.1	mg/L	0.0011	I	EPA 200.8	0.00035	3/11/14	16:49	E84129
1024	Cyanide	0.2	mg/L	0.0024	U	SM 4500CN-E	0.0024	3/12/14	16:00	E84129
1025	Fluoride	4.0	mg/L	0.19		EPA 300.0	0.010	3/6/14	3:26	E84129
1030	Lead	0.015	mg/L	0.00025	U	EPA 200.8	0.00025	3/11/14	16:49	E84129
1035	Mercury	0.002	mg/L	0.00010	U	EPA 245.1	0.00010	3/12/14	13:38	E84129
1036	Nickel	0.1	mg/L	0.00046	U	EPA 200.8	0.00046	3/11/14	16:49	E84129
1045	Selenium	0.05	mg/L	0.00093	U	EPA 200.8	0.00093	3/11/14	10:19	E84129
1052	Sodium	160	mg/L	3.2		EPA 200.7	0.13	3/6/14	16:43	E84129
1074	Antimony	0.006	mg/L	0.0010	U	EPA 200.8	0.0010	3/11/14	10:19	E84129
1075	Beryllium	0.004	mg/L	0.000096	U	EPA 200.7	0.000096	3/6/14	16:43	E84129
1085	Thallium	0.002	mg/L	0.00024	U	EPA 200.8	0.00024	3/11/14	16:49	E84129

*Qualifiers:

U=Analyte was undetected; Indicated concentration is method detection limit.
 I=The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.



**Florida Department of Environmental Protection
 Safe Drinking Water Program Laboratory Reporting Format**

SECONDARY CONTAMINANTS
 62-560.320

Report Number / Job ID: 1402335-01
 PWS ID (From Page 1): _____

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
1002	Aluminum	0.2	mg/L	0.050	U	EPA 200.7	0.050	3/6/14	16:43	E84129
1017	Chloride	250	mg/L	3.5		EPA 300.0	0.050	3/6/14	3:26	E84129
1022	Copper	1	mg/L	0.00098		EPA 200.8	0.00013	3/11/14	16:49	E84129
1025	Fluoride	2.0	mg/L	0.19		EPA 300.0	0.010	3/6/14	3:26	E84129
1028	Iron	0.3	mg/L	0.020	U	EPA 200.7	0.020	3/6/14	16:43	E84129
1032	Manganese	0.05	mg/L	0.0010	U	EPA 200.7	0.0010	3/6/14	16:43	E84129
1050	Silver	0.1	mg/L	0.000069	U	EPA 200.8	0.000069	3/11/14	16:49	E84129
1055	Sulfate	250	mg/L	1.3		EPA 300.0	0.20	3/6/14	3:26	E84129
1095	Zinc	5	mg/L	0.0017	I	EPA 200.8	0.00088	3/11/14	16:49	E84129
1905	Color	15	CU	5	U	SM 2120B	5	3/5/14	11:23	E84129
1920	Odor @ 25C	3	TON	1		SM 2150B	1	3/5/14	10:35	E84129
1930	Total Dissolved Solids	500	mg/L	110		SM 2540C	10	3/10/14	8:53	E84129
2905	Foaming Agents	0.5	mg/L	0.048	U	SM 5540C	0.048	3/5/14	13:27	E84129

*Qualifiers:

U=Analyte was undetected. Indicated concentration is method detection limit.
 I=The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.



**Florida Department of Environmental Protection
 Safe Drinking Water Program Laboratory Reporting Format**

DISINFECTANT BYPRODUCTS
 Report Number / Job ID: 1402335-01
 Disinfectant Residual (mg/L) (From Page 1):
 PWS ID (From Page 1):

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Reg MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
1009	Chlorite	1000	ug/L	10	U	EPA 300.1	10	20	3/6/14	11:56	E84129
1011	Bromate	10	ug/L	5.0	U	EPA 300.1	5.0	5.0	3/6/14	11:56	E84129
Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Reg MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2450	Monochloroacetic Acid	N/A	ug/L	0.82	U	EPA 552.2	0.82	2.0	3/12/14	4:53	E84129
2451	Dichloroacetic Acid	N/A	ug/L	0.73	U	EPA 552.2	0.73	1.0	3/12/14	4:53	E84129
2452	Trichloroacetic Acid	N/A	ug/L	0.37	U	EPA 552.2	0.37	1.0	3/12/14	4:53	E84129
2453	Monobromoacetic Acid	N/A	ug/L	0.36	U	EPA 552.2	0.36	1.0	3/12/14	4:53	E84129
2454	Dibromoacetic Acid	N/A	ug/L	0.28	U	EPA 552.2	0.28	1.0	3/12/14	4:53	E84129
2455	Total Haloacetic Acids (HAA5)	60	ug/L	0.28	U	EPA 552.2	0.28	—	3/12/14	4:53	E84129
Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Reg MRL**	Analysis Date	Analysis Time	DOH Lab Certification #
2941	Chloroform	N/A	ug/L	0.2	U	EPA 524.2	0.2	1.0	3/13/14	16:53	E84129
2942	Bromoform	N/A	ug/L	0.2	U	EPA 524.2	0.2	1.0	3/13/14	16:53	E84129
2943	Bromodichloromethane	N/A	ug/L	0.2	U	EPA 524.2	0.2	1.0	3/13/14	16:53	E84129
2944	Dibromochloromethane	N/A	ug/L	0.1	U	EPA 524.2	0.1	1.0	3/13/14	16:53	E84129
2950	Total Trihalomethanes (TTHM)	80	ug/L	0.1	U	EPA 524.2	0.1	—	3/13/14	16:53	E84129

** Laboratories are required to adhere to minimum reporting level (MRL) requirements of 40 CFR 141.131(b)(2)(iv). Chlorite regulatory MRL is applicable to monitoring as prescribed in 40 CFR 141.132(b)(2)(i)(B) and (b)(2)(ii). Laboratories that use EPA Methods 317.0 Revision 2.0, 326.0 or 321.8 must meet a 1.0 ug/L MRL for bromate.

*Qualifiers:

U=Analyte was undetected. Indicated concentration is method detection limit.



Florida Department of Environmental Protection
Safe Drinking Water Program Laboratory Reporting Format

VOLATILE ORGANICS
 62-550.310(4)(a)

Report Number / Job ID: 1402335-01
 PWS ID (From Page 1): _____

Contam ID	Contain Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	RDL	Analysis Date	Analysis Time	DOH Lab Certification #
2378	1,2,4-Trichlorobenzene	70	ug/L	0.3	U	EPA 524.2	0.3	0.5	3/13/14	16:53	E84129
2380	dis-1,2-Dichloroethylene	70	ug/L	0.09	U	EPA 524.2	0.09	0.5	3/13/14	16:53	E84129
2855	Xylenes (total)	10,000	ug/L	0.1	U	EPA 524.2	0.1	0.5	3/13/14	16:53	E84129
2864	Dichloromethane	5	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2968	o-Dichlorobenzene	600	ug/L	0.1	U	EPA 524.2	0.1	0.5	3/13/14	16:53	E84129
2969	para-Dichlorobenzene	75	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2676	Vinyl chloride	1	ug/L	0.3	U	EPA 524.2	0.3	0.5	3/13/14	16:53	E84129
2977	1,1-Dichloroethylene	7	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2979	trans-1,2-Dichloroethylene	100	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2980	1,2-Dichloroethane	3	ug/L	0.1	U	EPA 524.2	0.1	0.5	3/13/14	16:53	E84129
2981	1,1,1-Trichloroethane	200	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2982	Carbon tetrachloride	3	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2983	1,2-Dichloropropane	5	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2984	Trichloroethylene	3	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2985	1,1,2-Trichloroethane	5	ug/L	0.2	U	EPA 524.2	0.2	0.5	3/13/14	16:53	E84129
2987	Tetrachloroethylene	3	ug/L	0.1	U	EPA 524.2	0.1	0.5	3/13/14	16:53	E84129
2989	Monochlorobenzene	100	ug/L	0.1	U	EPA 524.2	0.1	0.5	3/13/14	16:53	E84129
2990	Benzene	1	ug/L	0.1	U	EPA 524.2	0.1	0.5	3/13/14	16:53	E84129
2991	Toluene	1000	ug/L	0.09	U	EPA 524.2	0.09	0.5	3/13/14	16:53	E84129
2992	Ethylbenzene	700	ug/L	0.08	U	EPA 524.2	0.08	0.5	3/13/14	16:53	E84129
2996	Styrene	100	ug/L	0.05	U	EPA 524.2	0.05	0.5	3/13/14	16:53	E84129

NOTE: Results indicating non-detection with a reported lab MDL > .5 ug/L will not be accepted for compliance.

*Qualifiers:

U-Analyte was undetected. Indicated concentration is method detection limit.



**Florida Department of Environmental Protection
 Safe Drinking Water Program Laboratory Reporting Format**

SYNTHETIC ORGANICS
 62-550.310(4)(b)

Report Number / Job ID: 1402335-01
 PWS ID (From Page 1):

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	RDL	Extraction Date	Analysis Date	Analysis Time	DOH Lab Certification #
2005	Endrin	2	ug/L	0.05	U	EPA 525.2	0.05	0.01	3/13/14	3/13/14	18:54	EB4129
2010	Lindane	0.2	ug/L	0.02	U	EPA 525.2	0.02	0.02	3/13/14	3/13/14	18:54	EB4129
2015	Methoxychlor	40	ug/L	0.02	U	EPA 525.2	0.02	0.1	3/13/14	3/13/14	18:54	EB4129
2020	Toxaphene	3	ug/L	0.52	U	EPA 508.1	0.52	1	3/13/14	3/13/14	4:28	EB4129
2031	Dalapon	200	ug/L	0.33	U	EPA 515.3	0.33	1	3/6/14	3/7/14	10:37	EB4129
2032	Diquat	20	ug/L	0.39	U	EPA 549.2	0.39	0.4	3/5/14	3/4/14	14:46	EB4129
2033	Enderhall	100	ug/L	6.7	U	EPA 548.1	6.7	9	3/11/14	3/17/14	14:49	EB4129
2034	Glyphosate	700	ug/L	2.7	U	EPA 547	2.7	6	3/4/14	3/4/14	20:01	EB4129
2035	Di(2-ethylhexyl)adipate	400	ug/L	0.07	U	EPA 525.2	0.07	0.6	3/13/14	3/13/14	18:54	EB4129
2036	Oxaryl (Vydate)	200	ug/L	0.88	U	EPA 531.1	0.88	2	3/12/14	3/12/14	2:04	EB4129
2037	Simazine	4	ug/L	0.03	U	EPA 525.2	0.03	0.07	3/13/14	3/13/14	18:54	EB4129
2039	Di(2-ethylhexyl)phthalate	6	ug/L	0.6	U	EPA 525.2	0.6	0.6	3/6/14	3/13/14	18:54	EB4129
2040	Picloram	500	ug/L	0.049	U	EPA 515.3	0.049	0.1	3/6/14	3/7/14	10:37	EB4129
2041	Dinoseb	7	ug/L	0.15	U	EPA 515.3	0.15	0.2	3/6/14	3/7/14	10:37	EB4129
2042	Hexachlorocyclopentadiene	50	ug/L	0.06	U	EPA 525.2	0.06	0.1	3/13/14	3/13/14	18:54	EB4129
2046	Carbolfuran	40	ug/L	0.60	U	EPA 531.1	0.60	0.9	3/12/14	3/12/14	2:04	EB4129
2050	Alarazine	3	ug/L	0.02	U	EPA 525.2	0.02	0.1	3/13/14	3/13/14	18:54	EB4129
2051	Alachlor	2	ug/L	0.03	U	EPA 525.2	0.03	0.2	3/13/14	3/13/14	18:54	EB4129
2063	2,3,7,8-TCDD (Dioxin)	0.03	ng/L	0.57	U	EPA 1613B	0.57	0.005	3/15/14	3/17/14	10:50	EB7688
2065	Heptachlor	0.4	ug/L	0.08	U	EPA 525.2	0.08	0.04	3/13/14	3/13/14	18:54	EB4129
2067	Heptachlor epoxide	0.2	ug/L	0.08	U	EPA 525.2	0.08	0.02	3/13/14	3/13/14	18:54	EB4129
2105	2,4-D	70	ug/L	0.10	U	EPA 515.3	0.10	0.1	3/6/14	3/7/14	10:37	EB4129
2110	2,4,5-TP (Silver)	50	ug/L	0.042	U	EPA 515.3	0.042	0.2	3/6/14	3/7/14	10:37	EB4129
2274	Hexachlorobenzene	1	ug/L	0.04	U	EPA 525.2	0.04	0.1	3/13/14	3/13/14	18:54	EB4129
2306	Benzol(a)pyrene	0.2	ug/L	0.02	U	EPA 825.2	0.02	0.02	3/13/14	3/13/14	18:54	EB4129
2326	Pentachlorophenol	1	ug/L	0.014	U	EPA 515.3	0.014	0.04	3/6/14	3/7/14	10:37	EB4129
2383	Polychlorinated biphenyls (PCBs)	0.5	ug/L	0.086	U	EPA 508.1	0.086	0.1	3/13/14	3/18/14	4:28	EB4129
2331	Dibromochloropropane	0.2	ug/L	0.0056	U	EPA 504.1	0.0056	0.01	3/7/14	3/7/14	22:35	EB4129
2946	Ethylene dibromide (EDB)	0.02	ug/L	0.0056	U	EPA 504.1	0.0056	0.02	3/7/14	3/7/14	22:35	EB4129
2959	Chlordane	2	ug/L	0.046	U	EPA 508.1	0.046	0.2	3/13/14	3/18/14	4:29	EB4129

*Qualifiers: ** Non-detects with a reported lab MDL <50% of the MCL are acceptable for compliance with 62-550.310(4)(b)

U=Analyte was undetected. Indicated concentration is method detection limit.



**Florida Department of Environmental Protection
 Safe Drinking Water Program Laboratory Reporting Format**

OTHER CONTAMINANTS

Report Number / Job ID: 1402335-01
 PWS ID (From Page 1): _____

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
N/A	1,1,1,2-Tetrachloroethane	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	1,1,2,2-Tetrachloroethane	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	1,1-Dichloroethane	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	1,1-Dichloropropene	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	1,2,3-Trichlorobenzene	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	1,2,3-Trichloropropane	N/A	ug/L	0.4	U	EPA 524.2	0.4	3/13/14	16:53	E84129
N/A	1,3-Dichlorobenzene	N/A	ug/L	0.07	U	EPA 524.2	0.07	3/13/14	16:53	E84129
N/A	1,3-Dichloropropane	N/A	ug/L	0.1	U	EPA 524.2	0.1	3/13/14	16:53	E84129
N/A	2,2-Dichloropropane	N/A	ug/L	0.3	U	EPA 524.2	0.3	3/13/14	16:53	E84129
N/A	2-Chlorotoluene	N/A	ug/L	0.1	U	EPA 524.2	0.1	3/13/14	16:53	E84129
N/A	4-Chlorotoluene	N/A	ug/L	0.1	U	EPA 524.2	0.1	3/13/14	16:53	E84129
N/A	Bromomethane	N/A	ug/L	0.4	U	EPA 524.2	0.4	3/13/14	16:53	E84129
N/A	Chloroethane	N/A	ug/L	0.4	U	EPA 524.2	0.4	3/13/14	16:53	E84129
N/A	Chloromethane	N/A	ug/L	0.4	U	EPA 524.2	0.4	3/13/14	16:53	E84129
N/A	cis-1,3-Dichloropropene	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	Dibromomethane	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	Dichlorodifluoromethane	N/A	ug/L	0.5	U	EPA 524.2	0.5	3/13/14	16:53	E84129
N/A	Methyl-t-butyl ether	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	Naphthalene	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	trans-1,3-Dichloropropene	N/A	ug/L	0.1	U	EPA 524.2	0.1	3/13/14	16:53	E84129

*Qualifiers:

U=Analyte was undetected. Indicated concentration is method detection limit.



**Florida Department of Environmental Protection
 Safe Drinking Water Program Laboratory Reporting Format**

OTHER CONTAMINANTS

Report Number / Job ID: 14023335-01
 PWS ID (From Page 1):

Contam ID	Contam Name	MCL	Units	Analysis Result	Qualifier*	Analytical Method	Lab MDL	Analysis Date	Analysis Time	DOH Lab Certification #
N/A	Trichlorofluoromethane	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	Xylene-m,p	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	Xylene-o	N/A	ug/L	0.2	U	EPA 524.2	0.2	3/13/14	16:53	E84129
N/A	Aldicarb	N/A	ug/L	0.47	U	EPA 531.1	0.47	3/12/14	2:04	E84129
N/A	Aldicarb Sulfone	N/A	ug/L	0.46	U	EPA 531.1	0.46	3/12/14	2:04	E84129
N/A	Aldicarb sulfoxide	N/A	ug/L	0.43	U	EPA 531.1	0.43	3/12/14	2:04	E84129
N/A	Phenol	N/A	ug/L	1.4	U	EPA 625	1.4	3/12/14	18:13	E84129
N/A	Monochloramine	N/A	mg/L	0.10	U,Q	SM 4500CHG	0.10	3/5/14	14:00	E84129
N/A	Chlorine Dioxide	N/A	mg/L	0.50	Q	SM 4500ClO2D	0.010	3/7/14	14:24	E84129
N/A	Chlorine, Total Residual	N/A	mg/L	0.010	U,Q	SM 4500CHG	0.010	3/7/14	11:20	E84129
N/A	Nitrate+Nitrite (N)	N/A	mg/L	0.14		EPA 300.0	0.02	3/6/14	3:26	E84129
N/A	Perchlorate, ClO4	N/A	ug/L	0.60	U	EPA 314.0	0.60	3/18/14	1:53	E84129
N/A	pH	N/A	SU	7.2	Q	SM 4500H-B	0.10	3/6/14	16:10	E84129
N/A	Turbidity	N/A	NTU	0.05	U	SM 2130B	0.05	3/6/14	10:54	E84129
N/A	Total Coliform			Present		m-Colibblue24	--	3/6/14	13:56	E84129
N/A	E. Coll			Absent		m-Colibblue24	--	3/6/14	13:56	E84129

*Qualifiers:

U=Analyte was undetected. Indicated concentration is method detection limit.
 Q=Sample held beyond the accepted holding time.

Client Name: Water Boy
 Project Name / Location: Annual Source Spotting Testing
 Contact / Phone: Corey Godfrey 941-744-8248

Matrix Codes:
 DW-Drinking Water WW-Wastewater
 SW-SurfaceWater SL-Sludge SO-Soil
 GW-Groundwater SA-Saline Water O-Other
 R-Resequent Water

SAL Job No.	Sample Description	Date	Time	Matrix	Composite	PARAMETER / CONTAINER DESCRIPTION		Inclusions / Remarks
						Grab	1	
01	Source Spotting	3-11-13	1230	DW	X	1	40mLV Na ₂ S ₂ O ₈ /MCAA 531.1 IBWA	Seal intact? <input type="checkbox"/> N/A Samples intact upon arrival? <input type="checkbox"/> N/A Received on cool? Temp _____ <input type="checkbox"/> N/A Proper preservation indicated? <input type="checkbox"/> N/A React within holding time? <input type="checkbox"/> N/A Volatiles not swapped/impurities? <input type="checkbox"/> N/A Proper containers used? <input type="checkbox"/> N/A
				R	X	3	40mLV Na ₂ S ₂ O ₈ 515.3 Prim	
02	Trip Blank					1	1LaG, Na ₂ SO ₃ 508.1, 525.2	
						1	1LP, Cool Misc Inorganics, Bromate, Turbidity, Chloramines, NO2-NO3	
						1	250mL P, H ₂ SO ₄ Nutrients	
						1	250mL P, HNO ₃ Metals	
						1	250mL P, Ascorbic Acid Cyanide	
						1	1LaG, Cool Odor	
						2	40mLV, EOA Chlorite	
						3	40mLV, Na ₂ S ₂ O ₈ 504.1-prim	
						1	1LaP, Na ₂ S ₂ O ₈ 549.2-prim	
						1	40mLV, NH ₄ Cl 548-prim	
						1	40mLV, Na ₂ S ₂ O ₈ 547-prim	
						2	125mL P, Na ₂ S ₂ O ₈ TC Mcolt Blue P=A	
						X	1/2 gal P, HNO ₃ GA, GB, 226-228, U	
						2	40mLV, Na ₂ S ₂ O ₈ 524 Prim, TTHM, G2 Unreg, naphthalene	
						2	1LaG, Cool 625-Phenol	
						3	40mLV, NH ₄ Cl 552	
						2	1LaG, Cool Dioxin-Subcontract	
						1	125mL P, Cool Perchlorate (sub)	

Container Provided: *Shuttle*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Container Provided: *[Signature]*
 Relinquished: *[Signature]*
 Date/Time: *3/11/13 1230*
 Received: *[Signature]*
 Date/Time: *3/11/13 1230*

Chain of Custody

SOUTHERN ANALYTICAL LABORATORIES, INC.

110 BAYVIEW BOULEVARD, OLDSMAR, FL 34677 813-855-1844 FAX 813-855-8218

Florida Department of Environmental Protection

Safe Drinking Water Program Laboratory Reporting Format



Water Boy, Inc.
Annual Source Spring Analyses

PUBLIC WATER SYSTEM INFORMATION (to be completed by sampler - please type or print legibly)

System Name: _____ PWS I.D. #:

System Type (check one): Community Nontransient Noncommunity Transient Noncommunity

Address: _____

City: _____ Zip Code: _____

Phone: _____ Fax: _____ E-Mail Address: _____

SAMPLE INFORMATION (to be completed by sampler)

Sample Number: 1402335-01 Sample Date: 3/4/14 Sample Time: 12:30 pm AM PM (Circle One)

Sample Location (be specific): Source Spring Location Code: _____

Disinfection Residual (Required when reporting results for trihalomethanes and haloacetic acids): _____ mg/L Field pH: _____

Sample Type (Check Only One) Reason (s) for Sample (Check all that apply)

- Distribution Routine Compliance with 62-550 Replacement (of Invalidated Sample)
- Entry Point (to Distribution) Confirmation of MCL Exceedance*
- Plant Tap (not for compliance with 62-550) Composite of Multiple Sites** Clearance (permitting)
- Raw (at well or intake)
- Max. Residence Time
- Ave. Residence Time
- Near First Customer

Sampling Procedure Used or Other Comments: _____

* See 62-550.500(6) for requirements and restrictions.
And 62-550.5.12(3) for nitrate or nitrite exceedances.

** See 62-550.500(4) for requirements and
attach a results page for each site

SAMPLER CERTIFICATION

I, _____ (Print Name) _____ (Print Title) do HEREBY CERTIFY

that the above public water system and sample collection information is complete and correct.

Signature: _____ Date: _____

Certified Operator #: _____ Phone #: _____ Sampler's Fax #: _____

Sampler's E-Mail: _____